



GOVT. OF ASSAM
OFFICE OF THE DIRECTOR,
FIRE AND EMERGENCY SERVICES, ASSAM, GUWAHATI.



SEE ROLE - 18(2)

No. F&ES/FPW/

FORM - (G)

Dated Guwahati the 19/4/22

To,

The Principal,
For Nazir Ajmal Memorial College of Education (B.Ed),
Barpukhuri, Jugijan Road, Hojai,
Dist:- Hojai, Assam.

RENEWAL OF NO OBJECTION CERTIFICATE IN RESPECT OF INBUILT FIRE FIGHTING/
FIRE PREVENTION AND MEANS OF ESCAPE MEASURES IN **THE NAZIR AJMAL MEMORIAL
COLLEGE OF EDUCATION (B.ED) LOCATED AT BARPUKHURI, JUGIJAN ROAD, HOJAI,
DIST:- HOJAI, ASSAM.**

With reference to your completion report under No. Nil Dated 03.03.2022

and on the basis of the Inspection Report submitted by Sr. Station Officer, Piku Moni Das I hereby certify that the building as per description below at Dag No. 330 Patta No. 82 Mouza **Jugijan, (Place- Barpukhuri, Hojai)** has been inspected in respect of implementation of inbuilt Fire Fighting/ Fire Prevention/ Escape means measures and is declared fit in respect of fire safety. The Fire & Emergency Services, Assam has No Objection in its occupation /utilization for the purpose of **COLLEGE** subject to conditions mentioned over leaf.

DETAILS OF APPROVED OCCUPATION:-

GROUND FLOOR:-

1. Floor area: - 2276.55 m²

2. Purpose of utilization: -
For College Purpose.

FIRST FLOOR:-

1. Floor area: - 1674.93 m²

2. Purpose of utilization: -
For College Purpose.

SECOND FLOOR:-

1. Floor area: - 1625.77 m²

2. Purpose of utilization:-
For College Purpose.

Details of Fire Fighting measures found in working condition:

1. Hose Reel Hose system
2. Down Comer system
3. Manually Operated Electric Fire Alarm system
4. Fire Extinguishers- 18 Nos.
5. Terrace Water Tank
6. Fire Pump

S.P. cum F&ES Adviser
for and on behalf of
Director of Fire and Emergency Services, Assam
Guwahati.

Dated Guwahati the _____

NO. F&ES/FPW/

Copy to:-

1. The Deputy Commissioner, **Hojai**, Assam for information.
2. The Superintendent of Police, **Hojai** Assam for information.
3. The Chairman, **Hojai Municipal Board**, Assam for information.
4. The Sr. Station Officer, **Hojai F&ES Station**, for information and necessary action.

S.P. cum F&ES Adviser,
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati.

CONDITIONS:-

1. The N.O.C. is valid up to: - **31.03.2023**
2. There should not be any change of Trade for which this License has been issued.
3. There should not be any structural change in the building either horizontally or vertically. There should not also be any change in the existing arrangements.
4. The Fire Fighting equipments should be in serviceable condition at all time.
5. Water reservoir should always be kept full up to brim.
6. The entrance and exit and the water reservoir should always be free from any obstruction/ projection.
7. **The N.O.C. is liable to be cancelled if the premises (for which the N.O.C. is granted) when inspected are not found conforming to the description and condition under which this N.O.C. is granted.**

S.P. cum F&ES Adviser
for and on behalf of
Director of Fire and Emergency Services,
Assam
পদবাহী
পদবাহী

S.P. CHIT P. & E.S.A.
Fire & Emergency Services, Assam
পদবাহী